



# Overview of the RELAP5-3D code activities in ENEA


**C. Parisi, P.Balestra, A. Del Nevo, E.Negrenti**

***2013 International RELAP5 Users Group (IRUG) Meeting & Seminar***

**12-13 September 2013  
Idaho Falls, Idaho, USA**



- Recent activities using RELAP5-3D© code
  - OECD/NEA OSKARSHAMN-2 benchmark
  - AER DYN-003 benchmark
  - Gen. IV activities on Sodium Fast Reactor
- Conclusions & Future works





- ❑ RELAP5-3D code used for studying past, existing (Gen. II) & *future* (Gen. IV) NPP
- ❑ Participating to international code benchmarks organized by nuclear energy Institutions (OECD/NEA, AER, IAEA)
  - **“OSKARSHAMN-2”**: BWR global core instability event (OECD/NEA)
  - **“DYN-003”**: CR Ejection in VVER-440 (AER)
  - **“EBR-II”**: pump coast-down transient (IAEA)
- ❑ **Objectives:**
  - ❑ to investigate the capabilities of codes in simulating NPP behaviors
  - ❑ to quantify codes and models uncertainties
  - ❑ to **increase** and **improve** *user experience*

## ❑ OSKARSHAMN-2 benchmark


- Launched by OECD/NEA in 2011 → release 2.0 of specifications
- Previous instability benchmarks (Forsmark and Ringhals) characterized by decay ratio  $< 1.0$  & based on noise measurement of a stable reactor
- **O-2** 1999 event is an instability event with a DR  $> 1$  (diverging oscillation)
- Challenging simulation for a coupled code
  - Detailed RPV/core nodalization needed
  - Core parameters changing on a great magnitude
    - Core power going from 100% to 60%, then up to 130%
  - Tightly coupled NK-TH transient

# The 1999/02/25 event



Event Description	
1	Turbine trip and bypass valves opening
2	First 108% power level exceeding
3	Stop Reducing pump velocity
4	Second 108% power level exceeding
5	Stop Reducing pump velocity
6	Third 108% power level exceeding
7	Stop Reducing pump velocity
8	Operator Partially scrammed the reactor and reduced to the minimum the pump velocity.
9	Reactor enter in the unstable region of the power/flow map
10	The reactor scrammed because the power exceeded 132 %


## RELAP5-3D© used for the Oskarshamn-2 benchmark



# Reactor Coolant System modelling

## □ RCS TH nodalization

- Number of Hydraulic volumes: **489** (core channels and bypass not included)
- **4** recirculation loops with external pumps (collapsed in one)
- **4** steam lines (collapsed in one)
- Passive Heat structures still not simulated








# Core TH & NK nodalization

## □ Base model: Core Axial meshing:

- Uniform meshing for the active part **25**  
Hydraulic mesh + **25** Thermal mesh + **25**  
Neutronic mesh
- **3** Hydraulic mesh + **2** Neutronic mesh for  
the bottom & top reflector
- **1** Hydraulic meshes for FA inlet zone

## □ Core statistics

- **444** independent TH channels + **1** (Bypass)
- **12876** Hydraulic volumes + **29** (Bypass)
- **14472** NK nodes (including Reflector)





# Steady state analysis results

NAME	u.d.m	NPP	NPP Code	RELAP5-3D	Rel. error
Reactor Power	MW	1798.6	1802	1798.6	IMPOSED
Steam Dome Pressure	MPa	6.93	7.00	6.93	0.00%
Core Inlet Pressure	MPa	N/A	7.166	7.087	-1.11%
Core Outlet Pressure	MPa	N/A	7.067	6.988	-1.12%
Core $\Delta P$	kPa	N/A	98.8	98.6	-0.23%
Channel $\Delta P$	kPa	N/A	46.0	48.2	4.72%
Orifice & Lwr plate $\Delta P$	kPa	N/A	52.8	50.4	-4.54%
Core Average Void	//	N/A	0.42	0.44	3.79%
Core Average Fuel Temp	K	N/A	816.7	813.08	-0.44%
Feed water Temperature	K	457.6	N/A	457.6	IMPOSED
Core Inlet Temperature	K	547.30	548.05	546.99	-0.06%
Steam Temperature	K	N/A	N/A	557.83	N/A
Pump Speed	Rad/s	N/A	N/A	99.45	N/A
Total Core Flow Rate	kg/s	5474.0	5515.9	5474.0	0.00%
Active Core Flow Rate	kg/s	N/A	4793.5	4757.1	-0.76%
Steam Flow Rate	kg/s	900.0	976.0	903.8	0.42%
Downcomer Water Level	m	N/A	N/A	8.4	N/A
K-eff	//	N/A	1.0026	1.0031	50 pcm





# Steady state analysis results

- Power Radial shape factor mass flow errors for all 444 FA







# Transient analysis results

## □ Boundary conditions




# Transient analysis results

## Recirculation MFR, SD Pressure, SL MFR, Power Flow map



# Transient analysis results

□ Homogeneous axial meshing model → damped oscillations



## □ Possible causes:

- **Numerical diffusion**, which has a strong dampening effect using first-order discretization methods
- Not well-defined **boiling height**, caused by too large mesh at the bottom of the core

## □ Solution:


- Use an heterogeneous axial mesh, proportional to the velocity of the dominant phase, to obtain a Courant number in each mesh as close as possible to the unity (minimize numerical diffusion)
- Increase the number of mesh, improving the refinement → problem: limitation from the maximum available number of zones → switch from the original 444 TH channel model to a 222 TH channel model (use half core symmetry)

# Transient analysis results

- Currently testing 4 different models




**U25:** 25 identical mesh  
Max time step: 0.01s




**NU25:** 25 mesh to optimize the  
Courant number  
Max time step: 0.03s



**G7:** the first 7 halved and the last five  
doubled  
Max time step: 0.015s




**U50:** 50 identical mesh  
Max time step: 0.005 s






# Transient analysis results

## Max and Average Core Courant number Axial profile




# Transient analysis results

- New Max and Average Core Courant number of the **NU25** model




# Transient analysis results

## □ Oscillations using The Different Models



# Transient analysis results


## □ Total core Power (NU25 $T_s=0.03$ s)



# Conclusions on O2 & Future works




- ❑ Core Axial Meshing transient solution **influence** identified → **finding the converged solution** by performing **sensitivities** on **axial meshes/ time steps**
- ❑ **Limitation** on TH mapping did not allow to connect 1:1 the TH volumes & NK nodes (9999 zone figures available vs., e.g.  $444 \times 25 = 11100$  requested) → “homogenization” or reduce TH channels
- ❑ Future further steps for the model qualification:
  - Use NESTLE compatible X-Section library using **NEMTAB** data format (being released in these weeks)
  - Use the new INL-developed neutronic package, **PHISICS**, to take advantage of the features introduced in this new code and overcome some NESTLE limitations (e.g., XSec on-line interpolation)



# AER DYN003 benchmark

- ❑ 3D NK TH CR  
Ejection simulation
- ❑ VVER440 reactor
- ❑ 3 Types of Fuel  
+Ref.
  - “1”: 1.6%
  - “2”: 2.4%
  - “3”: 3.6%
  - “5”: Ref.
- ❑ Delayed neutrons  
groups specified:  $\beta$   
= 0.005 (maximize  
reactivity insertion)




# Core model

- ❑ Core 250 cm height
- ❑ CR partially inserted (2m)
- ❑ Eccentric CR ejected in 0.16 sec., speed = 12.5 m/s
- ❑ Feedbacks described by the following dependences:


- $\Sigma \downarrow i = \Sigma \downarrow i,0 + a \downarrow i (\sqrt{T \downarrow f} - \sqrt{T \downarrow f,0})$
- $\Sigma \downarrow i = \Sigma \downarrow i,0 + b \downarrow i (\rho \downarrow c - \rho \downarrow c,0)$

- ❑ 10.0 seconds simulation to be run
- ❑ 22 Axial layers
- ❑ Active zone of 20x12.5 cm
- ❑ Bottom and Top reflector of 25 cm
- ❑ Two BC for Reflector: XSections, Albedo



# Core model

- ❑ Full core, coupled model 349 thermal-hydraulic channels
- ❑ **1 hot channel** with the power of the hottest channel multiplied for 1.25
- ❑ Imposed Inlet and outlet pressure









# Steady State – Radial Power Distribution




## ❑ Reflector BC: Steady state comparison with independent solution



**NEM-REF**





**TPEN-REF**





# Steady State – Radial Power Distribution




☐ **Equivalent albedo BC:** Steady state comparison with independent solution



**NEM-REF**




**TPEN-REF**



# Transient: Core Power



## Core power



Case	CR worth " $\rho \downarrow \uparrow$ " (\$)	Rel. Error (%)
NEM-REF	1.9037	-3.31
TPEN-REF	2.0666	5.0751
TPEN-ALB	2.075	5.5013



# Transient: Core Power

- NEM-REF → Best Total core power prediction during transient



# Transient analysis results


## ■ NEM-REF Maximum fuel pellet centerline temperature & Minimum DNB margin



# Conclusions on AER-DYN003 activity



- ❑ CR ejection event for VVER440 reproduced by RELAP5-3D
- ❑ Good agreement for TH calculations, R5-3D less conservative than the other TH modules
- ❑ Some discrepancies between the RELAP5-3D and the independent solutions
  - **NEM** has **larger deviation for the SS** compared to the reference solution but...**correctly predict the transient** (power peak magnitude and timing)
  - **TPEN** has **small deviation for the SS** compared to the reference solution but..**overpredict and anticipate** the power peak




# Gen IV: EC FP7 PELGRIMM PROJECT: TH contribution




## 1. Set up of a R5-3D© nodalization of CP-ESFR for fast steady state and transient analysis

- **Main features:** 8 channels core; 1 equivalent MCP and HEX
- **Status:** nodalization development (completed)



## 2. Set up of a R5-3D© nodalization for detailed core study, modeling from MCP outlet to core outlet

- **Main features:** 3D TH model, core channel by channel model
- **Radial/axial power distribution** → from detailed Monte Carlo MCNPX code calculations
- **Status:** Nodalization development (in progress).  
Qualification of FA pressure drop and heat exchange (completed)



## 3. Set up of a R5-3D© and “Transuranus” code model for

- performing subchannel analysis aimed at evaluating FA performances and BIC for fuel pin behavior calculations
- executing fuel pin calculations



# Gen. IV: IAEA EBR-II Benchmark

The aim of the activity is to **validate** the numerical tools (i.e. TH-SYS and coarse mesh CFD codes) and the methodology to perform safety analysis of fast reactor systems

- Blind calculations and post analysis plus sensitivities to evaluate the accuracy in simulating the transient
- 4 yrs program from kick off Meeting (June 2012)

## □ Current nodalization features

- EBR-II primary system modeled with
  - ❖ 1 MULTID [R=6,  $\Theta$ =12; z=23]
  - ❖ 127 pipes → the 127 driver channels
  - ❖ Outer blanket zone modeled with 24 eq. tubes (i.e. 12 eq. reflector channels; 12 blanket)
  - ❖ Z-pipe; HEX, pumps and high and low pressure line modeled with 1D components.
- Secondary side modeled with 1D components








# IAEA EBR-II Benchmark

## □ Current status

- Nodalization of EBR-II by RELAP5-3D code under development (i.e. TH part + HS of core and SG completed; passive HS and control being completed)
- Fuel channels pressure drops and heat transfer performances evaluated
- Flow distribution at fuel channel inlet in progress
- Possible future coupling with **PHISICS** for **3D NK TH** transient simulations



# Conclusion & future steps



- ❑ ENEA is using R5-3D code as the reference tool for NPP simulation
- ❑ Participating to international benchmarking activities:
  - ❑ OECD/NEA Oskarshamn-2 BWR
  - ❑ AER “DYN-003”
  - ❑ IAEA “EBR-II”
- ❑ Using R5-3D in EC funded project for Gen. IV fuel development (**PELGRIMM** project)
- ❑ Future works (in collaboration with INL): **PHISICS/R5-3D** V&V and development

