



GFR-He/CO₂ Analysis Using RELAP5/ATHENA

Theron D. Marshall, PhD

August 26, 2004

Outline of Presentation

- *Gen-IV, Gas-cooled Fast Reactor concept*
 - *Looking beyond the Next Generation Nuclear Plant*
- *Impetus for Safety Analysis*
 - *Is passive safety inherently safe?*
- *The Large-Break LOCA*
 - *One of the most severe GFR challenges*
- *RELAP5/ATHENA Input Model*
- *Modeling Predictions*
 - *What the numbers imply*
- *Conclusions*




Background

Idaho National Engineering and Environmental Laboratory

What is the Gen-IV GFR Reactor Concept?

- *Has design specifications of:*
 - *being inherently safe*
 - *using direct Brayton cycle energy conversion with the He option*
 - *featuring high outlet temperatures, which increase thermal efficiency and suggest H₂ production*



GFR – Looking beyond the NGNP


- *Anticipated deployment: 2025*
- *Neutron flux of 1×10^{14} n/cm²-s*
- *Power density of 55 MW/m³ to 100 MW/m³*
- *Reference core configuration and fuel:*
 - *Plate/block, UC with SiC matrix*
- *Optional core configuration and fuel:*
 - *pin, U-Zr CERMET*
- *Reference core coolant:*
 - *He at 7 MPa [490 °C {in}, 842 °C {exit}]*
- *Optional core coolant:*
 - *CO₂ at 20 MPa [400 °C {in}, 550 °C {exit}]*




Background

Idaho National Engineering and Environmental Laboratory

GFR, NGNP – a difference in flow direction



NGNP with concentric inlet/outlet and downward flow through core



GFR with concentric inlet/outlet and upward flow through core



Impetus for Safety Analysis

- *Gen-IV reactor concepts have the directive of having enhanced safety systems*
- *Ideally the reactors will circumvent an accident scenario with minimal operator intervention*
- *The high power density of the GFR will effectively challenge any Decay Heat Removal System (DHRS)*
- *A passively-safe GFR DHRS may require innovative components and engineering design*
- *Safety analyses and experiments are necessary to validate any DHRS designs*



Challenge of the Large-Break LOCA


- *A double guillotine break of the inlet and outlet legs*
- *Decay Heat: 13% [SCRAM], 1.5% [1 hr], 1.2% [2 hr] of 600 MW*
- *Gen-IV Objective:*
 - *Complete decay heat removal with a passive DHRS*
 - *DHRS should maintain temperature limits for a minimum time period of three days*
- *Maximum matrix temperature limit < 2000 °C*



ATHENA Model: GFR Specifications


- *Coolants: He and S-CO₂*
- *Fuel: UC with SiC matrix*
- *TiN radial reflector and BC neutron shield*
- *Overview of system parameters:*

System Parameter	He	S-CO₂
<i>Power Level</i>	<i>600 MW_{th}</i>	<i>600 MW_{th}</i>
<i>Coolant Pressure</i>	<i>7 MPa</i>	<i>20 MPa</i>
<i>Inlet Temperature</i>	<i>490 °C</i>	<i>400 °C</i>
<i>Outlet Temperature</i>	<i>850 °C</i>	<i>550 °C</i>
<i>Mass Flow Rate</i>	<i>330 kg/s</i>	<i>3260 kg/s</i>
<i>Inlet Flow Area</i>	<i>8.35 m²</i>	<i>8.35 m²</i>
<i>Outlet Flow Area</i>	<i>6.42 m²</i>	<i>6.42 m²</i>
<i>Reactor Cavity Cooling System (RCCS)</i>	<i>GA-MHR</i>	<i>GA-MHR</i>




ATHENA Model: GFR Core Cross Section

Core Parameter	Value
<i>Thermal Power</i>	<i>600 MW_{th}</i>
<i>Average Power Density</i>	<i>50 MW/m³</i>
<i>Axial Power Peaking</i>	<i>1.25</i>
<i>Core Height</i>	<i>1.7 m</i>
<i>Fuel Assemblies</i>	<i>127</i>
<i>Width of Fuel Assembly</i>	<i>20 cm</i>
<i>Coolant Holes/Assembly</i>	<i>91</i>
<i>Coolant Void Fraction</i>	<i>40 %</i>





ATHENA Model: Unit Cell Heat Structure



Bound Research Task

Idaho National Engineering and Environmental Laboratory




ATHENA Model: Hydraulic Nodalization



Bound Research Task

Idaho National Engineering and Environmental Laboratory



ATHENA Model: Conduction Circuit



Bound Research Task

Idaho National Engineering and Environmental Laboratory


ATHENA Model: Core Nodalization



Bound Research Task

Idaho National Engineering and Environmental Laboratory


ATHENA Model: Radiation Circuit



Bound Research Task

Idaho National Engineering and Environmental Laboratory

ATHENA Model: Core, Containment, RCCS



ATHENA Model: Input Deck Specifics

- *Heat Structures:* 134
- *Mesh Points:* 725
- *Hydrodynamic Volumes:* 144
- *Volume:*
 - *Coolant (He/CO₂):* 6,608 m³
 - *RCCS (air):* 816 m³
- *Mass:*
 - *He Coolant:* 9,348 kg
 - *CO₂ Coolant:* 44,402 kg
 - *RCCS* 947 kg





ATHENA Model: Boundary Conditions

- *Specified:*
 - *coolant inlet temperature [490°C, He] [400°C, CO₂]*
 - *coolant outlet temperature [842°C, He] [550°C, CO₂]*
- *Calculated:*
 - *coolant flow rate calculated during steady state to provide desired outlet plenum temperature*
- *Assumed:*
 - *SCRAM curve of PWR*
 - *No gamma/neutron heating in reflector/shield*
 - *Containment pressure maintained [~0.8 MPa, He] [~1.8 MPa, CO₂]*
 - *RCCS is the DHRS (baseline case)*




Overview of ATHENA Steady-State Analysis

- *Steady-State Analysis*
 - *determined by constant containment temperature*
 - *volumetric heat capacity decreased by factor of 100*
 - *problem time of 4,200 s*



Overview of ATHENA Transient Analysis

- *LB-LOCA Transient*
 - *problem time reset to 0 s*
 - *valves open coolant loop to containment at 10 s*
 - *SCRAM starts at 10 s and finishes at 14 s*
 - *Problem time: 180,000 s (50 hrs)*




Understanding the Results


Idaho National Engineering and Environmental Laboratory

He Case Approaches Matrix Temp. Limit*


CO₂




He



*Containment pressure maintained



Containment Pres. Enhances Heat Transfer



$$Q = \dot{m} \cdot C_p \cdot \Delta T$$

$$\dot{m} = \rho \cdot A \cdot V$$


Containment Volume: 6,063 m³



Understanding the Results

Idaho National Engineering and Environmental Laboratory


Containment Temp. Means More Design Work



Understanding the Results

Idaho National Engineering and Environmental Laboratory

Vessel Temperature Is A Design Challenge




Understanding the Results


Idaho National Engineering and Environmental Laboratory

CO₂ Downcomer Flow Shows Flow Reversal

CO₂



He



Conclusions and Future Work

- *The RELAP5 results compare well with expected temperature and pressure trends*
- *The temperature limit of the core matrix material may be reached when He is the coolant*
- *The densities of the two coolants play an important part in the DHRS performance*
- *Future work will include:*
 - *sensitivity studies on containment transient pressure*
 - *CO₂ injection for the He DHRS*
 - *Analysis with CERMET fuel pins*

