



Overview of the RELAP5-3D code activities in ENEA


C. Parisi, P.Balestra, E.Negrenti, M. Sepielli

2012 International RELAP5 User Group (IRUG) Meeting & Seminar

**23-24 October 2012
Sun Valley, Idaho, USA**



- Framework
- Recent activities using RELAP5-3D code
 - OECD/NEA KALININ 3 benchmark
 - OECD/NEA OSKARSHAMN-2 benchmark
- Conclusions



Framework - ENEA & the SIMING Lab



- ❑ **ENEA** is the Italian National Agency for New Technologies, Energy & Sustainable Economic Development
- ❑ A branch of **ENEA** actively involved in **researches** for fission nuclear power technology
 - Research Reactors (e.g., TRIGA & Tapiro)
 - Experimental Engineering (e.g., AP600 components testing)
 - Nuclear Material Characterization
 - Models & Simulation
 - Integrated Services (e.g., waste management)
 - Metrology & Radioprotection
 - Advanced Nuclear Systems (e.g., Gen IV, LFR)




TRIGA Reactor (1 MW)



TAPIRO Fast Neutron Source

- ❑ The **ENEA-SIMING Lab** performing R&D activities **NPP simulations & engineering simulators** at the Casaccia Research Center (Rome)

- ❑ Acting as *Technical Support Organization (TSO)* for the Italian Nuclear & Industrial Safety Authority (ISPRA)




Vapore TH facility



SPES-2


- ❑ RELAP5-3D code used for studying NPP transients and accidents
- ❑ Participating to coupled code benchmarks organized by OECD/NEA
 - **“KALININ-3”: VVER-1000 MCP-1 switch off @ HFP**
 - **“OSKARSHAMN-2”: BWR Global Core Instability Event**
- ❑ Objectives:
 - ❑ to explore the capabilities of the coupled codes in simulating NPP behavior during AOO/DBA
 - ❑ to quantify codes and models uncertainties



Recent activities using RELAP5-3D code


□ KALININ-3 benchmark

- Model developed in the past years
- Presented in the last IRUG meeting
- Final results being submitted to the benchmark organizers by the end of the year
- Primary & secondary circuits modeled
 - 3D TH components for RPV
 - 3D NK core model
 - Detailed TH nodalization for selected FA
- Demonstrated capabilities of RELAP5-3D in modeling core asymmetric coolant temperature perturbations with high resolution degree



□ OSKARSHAMN-2 benchmark


- Launched by OECD/NEA last year → release 1.0 of specifications
→ definition of several parameters still in progress
- Previous instability benchmarks (Forsmark and Ringhals) characterized by decay ratio < 1.0 & based on noise measurement of a stable reactor
- **O-2** 1999 event is an instability event with a DR > 1 (diverging oscillation)
- Challenging simulation for a coupled code
 - Detailed RPV/core nodalization needed
 - Core parameters changing on a great magnitude
 - Core power going from 60% up to 130%
 - Tightly coupled NK-TH transient



The Oskarshamn NPP





Reactor Coolant System modelling




Design operating conditions		
Rated thermal power	MWt	1700
Dome pressure	MPa	7.0
Steam flow rate	kg/s	900.0
Reactor pressure vessel geometry		
Internal height	m	20.0
Internal diameter	m	5.2
Weight	t	530.0
Wall thickness	mm	134.0
Core geometry		
Equivalent core diameter	mm	3672
Equivalent core height	mm	3712
Number of fuel bundles	-	444
Control rods		
Absorbing material	-	B ₄ C
Number of CR	-	109

The 1999/02/25 event



Event Description	
1	Turbine trip and bypass valves opening
2	First 108% power level exceeding
3	Stop Reducing pump velocity
4	Second 108% power level exceeding
5	Stop Reducing pump velocity
6	Third 108% power level exceeding
7	Stop Reducing pump velocity
8	Operator Partially scrambled the reactor and reduced to the minimum the pump velocity.
9	Reactor enter in the unstable region of the power/flow map
10	The reactor scrambled because the power exceeded 132 %


RELAP5-3D© used for the Oskarshamn-2 benchmark




Reactor Coolant System modelling

□ RCS TH nodalization


- Number of Hydraulic volumes: **489** (core channels and bypass not included)
- **4** recirculation loops with external pumps (collapsed in one)
- **4** steam lines (collapsed in one)
- Passive Heat structures still not simulated




- 4 Different FA type of different fuel vendors present in the core




Type 1



Type 2 & 3



Type 4




Core TH & NK nodalization

□ Core Axial meshing:


- Uniform meshing for the active part **25** Hydraulic mesh + **25** Thermal mesh + **25** Neutronic mesh
- **3** Hydraulic mesh + **2** Neutronic mesh for the bottom & top reflector
- **1** Hydraulic meshes for FA inlet zone

□ Core statistics

- **444** independent TH channels + **1** (Bypass)
- **12876** Hydraulic volumes + **29** (Bypass)
- **14472** NK nodes (including Reflector)



- ❑ Several Benchmark “Uncertainties” identified
 - Cross section library specifications (NEMTAB format still not available, CR specifications)
 - Channels pressure drop coefficients
 - Materials thermal capacity and conductivities
 - Configuration of the channel connection to the lower plenum
- ❑ Missing data replaced by engineering judgment and in-house developed tools (e.g., CASMO Xsec interpolator)







Steady state analysis results



NAME	u.d.m	NPP	NPP Code	RELAP5-3D	Rel. error
Reactor Power	MW	1798.6	1802	1798.6	IMPOSED
Steam Dome Pressure	MPa	6.93	7.00	6.94	0.12%
Core Inlet Pressure	MPa	N/A	7.166	7.095	-0.99%
Core Outlet Pressure	MPa	N/A	7.067	6.996	-1.00%
Core ΔP	kPa	N/A	98.8	98.5	-0.34%
Channel ΔP	kPa	N/A	46.0	50.8	10.36%
Orifice & Lwr plate ΔP	kPa	N/A	52.8	47.7	-9.66%
Core Average Void	//	N/A	0.42	0.44	4.19%
Core Average Fuel Temp	K	N/A	816.7	854.7	4.65%
Feed water Temperature	K	457.6	N/A	457.7	IMPOSED
Core Inlet Temperature	K	547.30	548.05	547.1	-0.03%
Steam Temperature	K	N/A	N/A	557.9	N/A
Pump Speed	Rad/s	N/A	N/A	99.78	N/A
Total Core Flow Rate	kg/s	5474.0	5515.9	5474.0	0.00%
Active Core Flow Rate	kg/s	N/A	4793.5	4759.7	-0.70%
Steam Flow Rate	kg/s	900.0	976.0	904.5	0.50%
Downcomer Water Level	m	N/A	N/A	8.4	N/A
K-eff	//	N/A	1.0026	1.0056	30 pcm

Steady state results


Mass Flow Rate, Pressure and Temperature convergence




Steady state analysis results

- Power Radial shape factor and relative error for all 444 FA

Radial power shape factor




Radial power shape factor Error (%)




Steady state analysis results

□ Axial core values



Axial power shape factor



Axial averaged fuel temperature




Axial averaged void fraction




Steady state analysis results

- Mass flow rate and relative error for all 444 FA

Mass flow rate (kg/s)




Mass flow rate Error (%)




Steady state analysis results

- Exit void fraction and P/G factor for all 444 FA

Exit void fraction







P/G Factor (MW/(kg/s))







Transient analysis results

Boundary conditions




Transient analysis results

Recirculation MFR, SD Pressure, SL MFR, Power Flow map




Transient analysis results

□ Total core Power



Transient analysis results


□ Average clad Temperature Vs. Hot Spot temperature



Transient analysis results





Animation





Sensitivity analysis results

□ +/- 10 % Heat Capacity of UO₂ and Clad





□ +/- 10 % GAP Conductance





Sensitivity analysis results

□ +/- 3 K feed water temperature



□ +/- 1 s CR insertion time



- ❑ Main issues during nodalization development/code run
 1. Limitation on TH mapping did not allow to connect 1:1 the TH volumes & NK nodes (9999 zone figures available vs. $444 \times 25 = 11100$ requested) → some “homogenization” needed → Q: is it possible to increase the zone figures number in future releases?
 2. Possibility to implement the large CASMO Xsec database (9999 compositions available) → conflicting with the input deck length → “Input too long” error message (R5v.3.0beta)
 3. Implementation of Xsec cross terms & “online” Xsec interpolation not possible



Conclusion & future steps



- ❑ ENEA is using R5-3D code as reference tool for NPP simulation
- ❑ Oskarshamn-2 BWR state-of-the-art model for RELAP5-3D© system code has been developed
 - detailed 3D neutronic coupled thermal-hydraulic model
 - developed for instability analyses → Oskarshamn-2 Feb. 1999 event
- ❑ Steady state and on transient preliminary qualification achieved
 - Main «uncertainties» of the data set identified and their effect on simulation result assessed
- ❑ Future steps for the model qualification: performing blind calculations simulating the 1999 O-2 stability tests