



Development of a 3D Neutron Kinetic-Thermal-hydraulic Model for an RBMK Reactor by RELAP5-3D[©] Code

C. Parisi, M. Cherubini, F. D'Auria

(San Piero A Grado Nuclear Research Group)

DIMNP – University of Pisa - ITALY

**2006 RELAP5-3D[©] Users Seminar
Holiday Inn SunSpree Resort – West Yellowstone – USA
16 – 18 August 2006**




Contents


- **Main Goal and Steps**
- **Thermal-hydraulic modeling**
 - **Qualification**
 - **Transient results**
- **Neutron Parameters Database**
- **RBMK peculiarities and 3D NK modeling**
 - **Qualification**
 - **Transients Results**
- **Conclusions**

Framework of the activities


- 12 units still in operation
- 1 unit under construction (Kursk 5)
- Development of Plants life extension (50 yrs)



**NEEDS TO
INCREASE & IMPROVE
KNOWLEDGE FOR
THIS TECHNOLOGY**



**TACIS Project
R2.03/97 part B**



- 1) Core
- 2) Water pipe
- 3) Reactor bottom plate
- 4) Group Distribution Header
- 5) Shield
- 6) Steam Drum
- 7) Steam Water Pipe
- 8) Reactor top plate
- 9) Refuelling machine
- 10) Reactor lid structure
- 11) Top reactor channel
- 12) Downcomers
- 13) Pressure Header
- 14) Suction header
- 15) Main Coolant Pump

RBMK Sketch




*A project funded
by the
European Union*



Main Goal & Steps 1/2


**Develop a reliable tool
for detailed 3D NK – TH
analyses of RBMK system**






Main Goal & Steps 2/2

- RELAP5-3D[®] had a central role in the assembled Chain of Codes for RBMK severe accidents analyses




TH modeling 1/5

**Relap5-3D[®]
nodalisation**



**sketch of the right
side**





TH modeling 2/5

Steam Drum

FW

Steam Line

ICV, MSV, BRU-K, BRU-D





TH modeling 3/5

Downcomers

Suction Header



Suction pipes

Pumps

Pressure Header

Group Distribution Header

Water lines







TH modeling 4/5

Core & Graphite stack

Graphite Gap


Steam water lines





TH modeling 5/5

Main modelled subsystems	Right side	Left side
Number of GDH	22	1
Number of Core channels	24	7
Number of Steam Drums	2	2
Number of Additional Absorber channels	1	1
Number of Pumps	4	4
Number of Bypass lines	4	4






Adopted code resources

Number of Nodes	4272
Number of Junctions	4411
Number of Heat structures	4561
Number of Mesh Points	32590
Number of active structures (fuel + graphite)	64

Qualification Process

Basic condition for TH system codes use:


- ✓ Frozen code version
- ✓ User qualification
- ✓ Nod. qualification process
 - ✓ Steady state
 - ✓ On transient





Qualification Process

Steady State level – Volume vs. Height





Qualification Process

Steady State level- DP vs. Length





Qualification Process - SS level

Nodalisation geometrical check

No	QUANTITY	Unit	Design	RELAP5	Acceptable Error (°)	Error	Notes
				right side			
				left side			
1	Circuit volume	m ³	<u>667.67</u>	<u>667.78</u>	1%	0.01%	For right side
3	Active structures heat transfer area (overall)	m ²	<u>5919.4 (fuel & PT)</u> 6712.0 (Graphite-Gap)	<u>5919.6</u> 5906.5	0.1%	<u>0.03%</u> -12%	Error on Graphite-Gap surface due to different geometry
5	Active structures heat transfer volume (overall)	m ³	<u>14.423</u> 378.7	<u>14.427</u> 408.44	0.2%	<u>0.02%</u> 7.8%	Error on Graphite-Gap surface due to different geometry
6	Volume vs. height curve	m ³	--	--	10%	5%	Max error







Qualification Process - SS level

Steady State demonstration:
20 selected parameters

N.	Quantity	Unit	Design	RELAP5		Acceptable Error (%)	Error		Notes	
				right side	left side					
1	Thermal power	MW	1629	1628.1	2%	0.05%				
			1583	1588.1		-0.3%				
2	DS pressure	MPa	6.86	6.861	6.862	0.1%	-0.01%	-0.03%	On all SD dome	
				6.859	6.859		0.01%	0.01%		
3	Core inlet temperature	°C	270	269		0.5%	0.37%			
				269			0.37%			
4	DS inlet temperature	°C	284	284.5		0.5%	0.1%			
				284.5			0.1%			
5	Average quality in the core exit	%	14.5	15.5		?				
				15.3						
6	DS feed water temperature	°C	165	165	0.5%	0.0%	Imposed Value			
7	Maximum fuel rod temperature surface	°C	?	298	10					
8	MCP speed	rad/s	104.2	104.7	1%	0.4%	Imposed Value			
				104.7		0.4%				
9	Pressure drop on the water line	MPa	0.5	0.496 ÷ 0.51	10%	0.8% ÷ - 2%		For 2.049 MW channel		
10	Pressure drop on the core			0.491 ÷ 0.497		1.8% ÷ 0.6%				
				0.64 ÷ 0.658		2.5% ÷ -0.15%				
11	Pressure drop on the steam-water line			0.392		0.654 ÷ 0.658	0.46% ÷ -0.15%			
12	Total pressure drop on the TC	MPa	1.549	0.376 ÷ 0.387	4% ÷ 1.3%					
				0.366 ÷ 0.369	6.6% ÷ 5.9%					
13	MCP head	MPa	1.51	1.512	10%	-0.13%	For all pumps			
14	PS total mass inventory	tons	?	801	2%					
15	DS mass inventory	m ³	85±?	89.5	91.4	2%	-5%	-7%	Liquid Fraction Volume	
				86.8	87.8		-2%	-3%		
16	Total loop coolant flow rate	Kg/s	5157.9	5185.2	2%	-0.5%				
			5103.9	5106		-0.04%				
18	Additional absorber flow rate	Kg/s	105.82	103.5	10%	2%				
			105	92.5		12%				
19	Balance between feed water and steam mass flow rate	%	0.0	0.6%	?					
				0.7%						
20	Average graphite temperature	°C	?	485	?					
				484						






Qualification Process - SS level





Qualification Process - SS level








Qualification Process

On Transient level

REPLICATION OF A SELECTED TEST

Qualitative evaluation

Accuracy quantification



LOSS of POWER

Comparison
with exp. data

~~FFT BM~~

Comparison with
Russian results







Qualification Process – On Transient

Time sequence of main events

Unipi Time (s)	Event	Russian Time (s)
0.	Loss of preferred AC power supply. Diesel generators start.	0.
0.4	Turbine isolation and regulation valves fully closed.	0.4
1.0	1 st AZ-5 command issued by CPS upon EPPS reading that turbine valve has closed. This signal is neglected in the simulation.	1.0
1.0	2 nd AZ-5 command issued as a result of pressure downstream turbine valve falling to 12 bar. This signal is credited in the simulation. Power begins to reduce. CPS rods start moving.	1.0
1.0	BRU-K valves start to open due to over-pressure. BRU-K operate as pressure controller with opening and closure set-points equal to 7.11 MPa and 6.86 MPa respectively	1.0
3.0	First group of MSV start to open.	226.
15.0	Diesel generators reach nominal loading.	15.0
55.0	2 EFWP starts.	55.0
180.	BRU-K valves are fully closed.	180.0
600.	BRU-D valves are closed.	600.
1090.	The operator switch off EFWP on level signal.	1211.
3000.	Final problem time	3000.






Qualification Process – On Transient






Qualification Process – On Transient





Qualification Process – On Transient


Steam Drum pressure vs. time





Qualification Process – On Transient


MSV group 1 Mass flow rate vs. time





Qualification Process – On Transient

Core Mass flow rate vs. time







Considerations on TH model

- The pioneering study (for UNIPI) of the RBMK reactor type gave the following results:
 - **Steady State level**: all the limits regarding the geometrical fidelity have been fulfilled; precision of few parameters should be improved (i.e. **SD mass inventory**)
 - **On transient level**: a qualitative comparison between Russian and UNIPI results shows some discrepancies (e.g. **MSV timing**)
- The same phenomena are predicted from both calculations (**SD pressure trend**)
- Lacking of measured values does not permit the application of the FFT-BM to quantify the accuracy of the obtained results
- The nodalisation is capable to reproduce the selected transient – **LOOP** – even though some improvements are necessary


Successive step → **development of 3D NK model**

RBMK 3D NK Peculiarities


- RBMK peculiarities:
 - Loosely coupled core
 - Large number of nodes (30000)
 - 2488 channels (1570 FC, 314 non-FC (AA, Axial detectors,..), and 604 Reflector Channels)
 - Complex neutron XSecs structure (graphite & fuel temp, water density, Xenon conc,.. feedbacks)
 - Different CR arrangements & type:
 - Up & Bottom Inserted
 - Manual CR, Shortened CR, Fast Acting Scram CR



Manual CR



Shortened CR




Fast CR



Neutron Database - Code


HELIOS:

- 1D- 2D neutron-gamma transport code for lattice burnup
- complete geometric flexibility
- Generate Few-Groups Macroscopic XSecs Libraries



```

NEM-Cross Section Table Input
* T Fuel      T Mod.    Rho Cool.  CXe
  3          4          6          0
*****
X-Section set #  1
Group No.  1
*****
Diffusion Coefficient Table
.5570000E+03 .8500000E+03 .1030000E+04 .5570000E+03 .7000000E+03
.8500000E+03 .1060000E+04 .1000000E+02 .1000000E+03 .3000000E+03
.5000000E+03 .7440000E+03 .9980000E+03 .1161020E+01 .1161020E+01
.1161000E+01 .1161440E+01 .1161430E+01 .1161420E+01 .1160100E+01
.1160100E+01 .1160090E+01 .1157710E+01 .1157680E+01 .1157680E+01
.1159020E+01 .1159020E+01 .1159010E+01 .1159440E+01 .1159420E+01
.1159410E+01 .1158080E+01 .1158060E+01 .1158060E+01 .1155670E+01
.1155650E+01 .1155640E+01 .1153360E+01 .1153330E+01 .1153300E+01
.1153740E+01 .1153710E+01 .1153700E+01 .1152930E+01 .1152360E+01
.1152340E+01 .1149940E+01 .1149910E+01 .1149890E+01 .1146530E+01
.1146480E+01 .1146460E+01 .1146920E+01 .1146850E+01 .1146830E+01
.1145540E+01 .1145490E+01 .1145470E+01 .1143070E+01 .1143020E+01
.1142980E+01 .1137150E+01 .1137100E+01 .1137090E+01 .1137520E+01
.1137460E+01 .1137460E+01 .1136130E+01 .1136080E+01 .1136050E+01
.1133630E+01 .1133580E+01 .1133550E+01 .1126540E+01 .1126500E+01
.1126480E+01 .1126880E+01 .1126840E+01 .1126800E+01 .1125490E+01
.1125440E+01 .1125400E+01 .1122970E+01 .1122890E+01 .1122850E+01
*****
Total Absorption X-Section Table
  
```



1D – 2D Transport Calculations


XSecs Libraries

- Database function of:
 - ✓ Exposure
 - ✓ Fuel temperature
 - ✓ Graphite temperature
 - ✓ Coolant density
- 675 Compositions
 - for fuel cells: 610
 - for non-fuel cells: 65




Neutron Database Generation 2/2


- Operational data obtained with radial & axial in-core detectors
- Reactor core divided axially into 10 layers with a height of 70.0 cm
- Upper and lower axial reflectors have a thickness of 30 cm
- All non-fuel cell type considered
- Validation of the **Neutron Cross Sections Database** by precise **Monte Carlo calculations**



Smolensk-3 NPP status at 16.10.1996



FC cell



MCR cell

- Graphite
- Zirconium Alloy (3125)
- UO₂
- Zirconium Alloy (3110)
- Coolant




- Graphite
- Zirconium Alloy (3125)
- Aluminum Alloy
- CR Channel Coolant
- Graphite
- UO₂
- Coolant
- Zirconium Alloy
- Absorber




RBMK TH/3D NK Model Developed

Economy of Code resources

- Number of Volumes : **4728**
- Number of Meshes for Heat Transfer : **32400**
- Number of Axial Meshes per TH channel : **20**
- Number of TH channels : **58**




3D NK Core Modeling & Qualification




NESTLE 3D NK model

- **29856** Neutron Kinetic Nodes
- All CR Types (Manual, Shortened, Safety), Axial Detectors & Additional Absorbers **Simulated**
- Bottom, Top and Radial Graphite **Reflector** Modelled

- Radial power peaking factor – 1.62
- Radial power distribution: RMS from 130 radial detectors – 7%
- Axial power distribution: RMS from 12 axial detectors – 8%



Axial Core Peaking Factor




2D Core Power



3D NK Sensitivity Analysis

- Several tests performed for axial power distribution changing NESTLE numerical methods
- Pure CMFD method resulted more robust than NEM for this core configuration






RBMK Transient Analyses


- Several Plant transients were proposed and analyzed in order to check the codes capabilities in modeling RBMK phenomena:
 - **CR Withdrawal ***
 - **CR Bank Withdrawal ***
 - **GDH Rupture**
 - **Flow Blockage in GDH ***
 - **Flow Blockage in FC ***
 - **CPS cooling LOCA**
- * = sample results given in next slides




Sample Results 1/3




RELAP5-3D[®] CR Bank Withdrawal
Local power



RELAP5-3D[®] CR Bank Withdrawal
Clad Temperature for affected zone




RELAP5-3D[®] CR Withdrawal
Total power




- CR system (**CPS**) operating at low pressure → CR / CR bank withdrawal at 0.4 m/s
- CR Bank withdrawal generated scram signal (Reactor Power 106% of Nominal Power)




Sample Results 2/3



RELAP5-3D[®] GDH Blockage
Flow oscillations in blocked FC




RELAP5-3D[®] GDH Blockage
Total Reactor Power




RELAP5-3D[®] GDH Blockage
Pressure Tubes temperature in affected FCs

- Time trend of the main events:
- **0.0 sec.** – onset of the GDH Blockage; coolant flowrate by the ECCS by-pass line
 - **5.0 secs.** – onset of mass flow oscillations in the affected FCs
 - **140 secs.** – Pressure tube reaches maximum temperature



RELAP5-3D[®] GDH Blockage
Clad temperatures in hot-FC




RELAP5-3D[®] GDH Blockage
Void fraction in affected FCs




Sample Results 3/3


- Fuel Channel blockage → reference transient for the TACIS Project → demonstration that Pressure Tube Rupture does not propagate → what happens to FC power?



RELAP5-3D[®] FC Blockage
Power in blocked FC and neighbor FCs



RELAP5-3D[®] FC Blockage
Pressure Tube temp. in blocked FC



RELAP5-3D[®] FC Blockage
Power in blocked FC and neighbor FCs

Conclusions

- ✓ A detailed **TH RBMK NPP nodalization** was developed
- ✓ **RELAP5-3D[©]** demonstrated capabilities in reproducing all TH phenomena of RBMK
- ✓ **3D NK model** was able to reproduce all reactor core peculiarities → good agreement with in-core plant data
- ✓ **RELAP5-3D[©] (NESTLE) - HELIOS** constitutes an **independent and valid alternative** to Russian system codes **KORSAR-BARS-UNK** (comparison executed)
- ✓ Future works in the framework of a PhD thesis: reproduction of transients at low power (e.g., Chernobyl accident)